### **Features**

- 1-channel isolated barrier
- 115/230 V AC supply
- · Input for approved dry contacts or SN/S1N sensors
- · Relay output
- · Fault indication output
- · Line fault detection (LFD)
- Up to SIL3 acc. to IEC 61508
- Up to PL d acc. to EN/ISO 13849

### **Function**

This isolated barrier is used for intrinsic safety applications.

The device transfers digital signals (SN/S1N proximity sensors or approved dry contacts) from a hazardous area to a safe area.

The input controls one output with 3 form A normally open relay contacts (one is in series to the 2 output relay contacts for the safety function), one output with 1 form A normally open relay contact, and one passive transistor output.


Unlike an SN/S1N series NAMUR proximity sensor, a mechanical contact, requires a 10 k $\Omega$  resistor to be placed across the contact in addition to a 1.5 k $\Omega$  resistor in series.

Lead breakage (LB) and short circuit (SC) conditions of the control circuit are continuously monitored.

During an error condition, fault output energizes and outputs I and II de-energize.

For safety applications up to SIL3, output I must be used.

# **Assembly**






#### Connection

Date of issue 2017-08-09 046904\_eng.xml

Release date 2017-08-0914:29



II

230 V AC

13

19

20 14 15

21 16+

22 23 24

Singapore: +65 6779 9091

pa-info@sg.pepperl-fuchs.com

046904_eng.xml	
Date of issue 2017-08-09	
5	
1 ISSUE	
14:29	
60-80-/	
5	
date	
Helease date 2017-08-09 14:29	

	Diata laura
	Digital Input
ameters	OH O
	SIL 3
	PL d
	terminals 22, 23, 24
	85 253 V AC , 45 65 Hz
I <sub>r</sub>	30 mA ± 5 mA
	2.2 W
	≤ 2.3 W
	field side
	terminals 10+, 12-
it current	approx. 8.4 V DC / approx. 11.7 mA
	$\leq$ 50 $\Omega$ , in hazardous area cable capacitances and inductivities are to be taken into account
	I < 2.1 mA and I > 5.9 mA
	2.8 mA < I < 5.3 mA
	≤1 ms
	control side
	output I: terminals 13, 14; output II: terminals 15, 21; output III: terminals 16+, 17-
	relay , signal
	253 V AC/1 A/cos φ ≥ 0.7; 24 V DC/1 A resistive load
	50 x 10 <sup>6</sup> switching cycles
	relay, signal
	253 V AC/1 A/cos $\phi \ge 0.7$ ; 24 V DC/1 A resistive load
	50 x 10 <sup>6</sup> switching cycles
	electronic output, passive, fault signal
	10 30 V DC
	1-signal: (L+) -2.5 V (7 mA, short-circuit proof) / 0-signal: blocked output
	(Leakage current ≤ 10 mA)
	5 Hz
	LEDs
	space for labeling at the front
	EN 61326-1:2013 (industrial locations)
	EN 61010-1:2010
	EN/ISO 13849-1:2008
	NE 21:2011
	IEC 60529:2001
	IEC/EN 61508:2010
	-20 60 °C (-4 140 °F)
	IP20
	screw terminals
	approx. 280 g
	40 x 93 x 115 mm (1.6 x 3.7 x 4.5 inch) , housing type E
	on 35 mm DIN mounting rail acc. to EN 60715:2001
ection	on 35 mm DIN mounting rail acc. to EN 60/15:2001
	on 35 mm DIN mounting rail acc. to EN 60/15:2001  PTB 00 ATEX 2043
ection	PTB 00 ATEX 2043
te	PTB 00 ATEX 2043  Il (1)GD [EEx ia] IIC [circuit(s) in zone 0/1/2]  EEx ia IIC
	PTB 00 ATEX 2043  (ix) II (1)GD [EEx ia] IIC [circuit(s) in zone 0/1/2]
	Ur Ir

Supply		
Maximum safe voltage	$U_m$	253 V AC/DC (Attention! The rated voltage can be lower.)
Output		
Contact loading		253 V AC/1 A/cos φ ≥ 0.7; 24 V DC/1 A resistive load
Maximum safe voltage	$U_m$	output I/output II: 253 V AC/DC (Attention! U <sub>m</sub> is no rated voltage.)
Galvanic isolation		
Input/Output		safe electrical isolation acc. to IEC/EN 60079-11, voltage peak value 375 V
Input/power supply		safe electrical isolation acc. to IEC/EN 60079-11, voltage peak value 375 V
Directive conformity		
Directive 2014/34/EU		EN 60079-0:2012+A11:2013 , EN 60079-11:2012
General information		
Supplementary information		Observe the certificates, declarations of conformity, instruction manuals, and manuals where applicable. For information see www.pepperl-fuchs.com.

## **Function**

The input (terminals 10, 12) may generally be operated only with potentially free (passive) switches.

Single channel operations up to SIL3 **must** occur via terminals 13 and 14. The center tap of the contacts (terminals 19, 20) can **also** be used if an operation is to occur a redundant branch.

If the device is used for safety operations the information in the test documents should be observed. The output III error message delivers a "1"-signal when the control circuit experiences lead breakage (LB) or a short circuit (LK).

The device (housing type E) has integrated terminals.

# Maximal switching power of the output

